



# TEALwatch

## Power Quality Analysis

Facility:	<b>Memorial Hospital</b> <b>1234 Mockingbird Lane</b> <b>Springfield, TX 12345</b>	Protected Equipment:	<b>Acme Phytoscan 4700</b>
TEAL Model #:	<b>PCDU-Phyto-U</b>	TEALWatch Serial #:	<b>00027</b>
TEAL Serial #:	<b>A-023456-1</b>	TEALwatch Site #:	<b>00010</b>
Primary Contact:	<b>Alfred Ganim</b>	TEALwatch Report #:	<b>00010A</b>
Company:	<b>Acme Medical Systems</b>	Secondary Contact:	<b>Karl Strauss</b>
Phone:	<b>(123) 456-7890</b>	Company:	<b>Strauss Consulting</b>
Email:	<b>Aganim@Acmeded.Com</b>	Phone:	<b>(818) 888-3434</b>
		Email:	<b>Kstrauss@Straussgroup.Com</b>

### Facility Electrical System / Power Monitoring Notes

Intermittant system resets and lock-ups

### Dates and Times of Interest

Date and Time	Event Description (Errors, Faults, Site Logs, Etc.)
1/19/05 10:47	System reboot (not in use)
1/21/05 7:45	Tube arc during air calcs
1/22/05 15:18	Artifact on image during high power scan

### Power Monitoring Information


Site Configuration:	<input checked="" type="checkbox"/> Wye <input type="checkbox"/> Delta	Data Supplied via:	<input type="checkbox"/> Direct Download <input checked="" type="checkbox"/> Email
Current Data:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Monitoring Comments:	<b>No Problems</b>
Trend Data Period:	<b>3 Days</b>	Voltage Events Logged:	<b>1 Week</b>
Received Data:	<b>11-Feb-05</b>	Report Generated:	<b>15-Feb-05</b>



Category	Analysis	Recommendations
<b>RMS Voltage Level</b>	RMS Voltage levels are acceptable. Lower voltage on 1/21/05 but within system requirements.	No Corrective Actions Recommended
<b>Voltage Waveform</b>	Voltage waveform is sinusoidal with a minimum of visible harmonic distortion.	No Corrective Actions Recommended
<b>Phase Imbalance</b>	Voltage phase balance is less than 2%.	No Corrective Actions Recommended
<b>Voltage Outages</b>	Two voltage outages were captured.	Utility related outages may impact equipment availability and patient throughput. We recommend an Uninterruptible Power Source (UPS) to ride through short voltage outages.
<b>Voltage Sags and/or Swells</b>	Several dropouts and line related sags were recorded. Check for an emergency power supply that might have switched during the monitored period.	Voltage sags and swells may cause equipment errors, lock-ups, or resets. In order to maximum equipment uptime at sites that experience frequent sags and swells, we recommend a UPS or power conditioner.
<b>Voltage Transients</b>	Low frequency ringing transients were recorded.	Consider a UPS or power conditioner to protect the system from low frequency transients, if unexplained or intermittent system problems can be correlated to these transients.  Conventional TVSS devices do not provide protection from this type of transient.
<b>Load Generated Events</b>	Several apparent load generated disturbances were captured, and may indicate excessive source impedance.	Check the facility service and branch circuits to ensure they meet equipment requirements for conductor size, transformer size, and ratings.




### RMS Voltage Snapshot



Voltage waveforms are sinusoidal, with a minimum of harmonic distortion.




### RMS Voltage Trend Data – Full Monitoring Period




**RMS Voltages were acceptable throughout the monitored period.**

**Voltage Balance was less than 1% throughout the monitored period.**




### RMS Voltage Trend Data – 24 Hour Period



**RMS Voltages were acceptable throughout the monitored period.**


**Voltage Balance was less than 1% throughout the monitored period.**



### Voltage Outage Event Summary

Event	Date and Time	Type	Minimum	Maximum	Duration
4	1/19/05 10:28:23	Power Loss	0	0	1
5	1/19/05 10:57:46	Power Loss	0	0	1

### Voltage Outage Events




**Event Number:** 4

**Date:** mm/dd/yyyy

**Time:** 10:28:23 AM

**Analysis**

Voltage was not applied at the start of the monitored period.



**Event Number:** 5

**Date:** 1/19/2005

**Time:** 10:57:46 AM

**Analysis**


Loss of voltage, appears to be a local switch-off of power, and not a utility or facility-wide voltage failure.




## Voltage Sag and Swell Summary

Event	Date and Time	Type	Minimum	Maximum	Duration
2	1/19/05 10:27:04	Voltage Sag	67.4	120.3	0.167
9	1/19/05 15:44:08	Voltage Sag	88.6	120	0.017
10	1/21/05 15:57:20	Voltage Sag	94	120.2	0.017
16	1/21/05 15:59:42	Voltage Sag	90.6	112.4	0.017

## Voltage Sag and Swell Events




**Event Number:** 2  
**Date:** 1/19/2005  
**Time:** 10:27:04 AM  
**Duration:** 0.167  
**Minimum:** 67.4 VAC  
**Maximum:** 120.3 VAC  
**Analysis**  
 Severe voltage sag on Phase A only.



**Event Number:** 9  
**Date:** 1/19/2005  
**Time:** 3:44:08 PM  
**Duration:** 0.017  
**Minimum:** 88.6 VAC  
**Maximum:** 120.0 VAC  
**Analysis**  
 1/2 cycle drop-out on Phase B only.




## Voltage Sag and Swell Events



**Event Number:** 10  
**Date:** 1/21/2005  
**Time:** 3:57:20 PM  
**Duration:** 0.017  
**Minimum:** 94.0 VAC  
**Maximum:** 120.3 VAC

### Analysis


Small step in RMS voltage, probably a utility sag or large load switch-on.



**Event Number:** 16  
**Date:** 1/21/2005  
**Time:** 3:59:42 PM  
**Duration:** 0.017  
**Minimum:** 90.6 VAC  
**Maximum:** 112.4 VAC

### Analysis

Step change in voltage waveform and amplitude, probably related to load switch-on and VRDU output impedance.



**Event Number:** 2  
**Date:** 1/19/2005  
**Time:** 10:27:04 AM  
**Duration:** 0.167  
**Minimum:** 67.4 VAC  
**Maximum:** 120.3 VAC

### Analysis


End of event 2, sag ends and voltage is restored.



## Voltage Transient and Sub-cycle Event Summary

Event	Date and Time	Type	Minimum	Maximum	Duration
1	1/19/05 10:26:53	Subcycle	-236.6	174.6	1
3	1/19/05 10:27:53	Subcycle	-236.8	174.6	1
7	1/19/05 15:44:05	Subcycle	-212.9	214.6	1
8	1/19/05 15:44:05	Subcycle	-197.5	197.8	1
11	1/21/05 15:58:07	Subcycle	-204.8	213.1	1
12	1/21/05 15:58:07	Subcycle	-198	200.9	1
13	1/21/05 15:59:23	Subcycle	-197.5	212.4	1
14	1/21/05 15:59:23	Subcycle	-199	202.4	1
15	1/21/05 15:59:40	Subcycle	-205.6	212.2	1
17	1/21/05 15:59:47	Subcycle	-200.4	213.4	1
18	1/21/05 15:59:47	Subcycle	-197.8	200.2	1
19	1/21/05 15:59:57	Subcycle	-208	210.2	1
20	1/21/05 15:59:57	Subcycle	-194.1	198.7	1

## Voltage Transient and Sub-cycle Events




**Event Number:** 1

**Date:** 1/19/2005

**Time:** 10:26:53 AM

**Analysis**

Low frequency transient, possibly related to utility switching or power factor capacitor switching.



**Event Number:** 3

**Date:** 1/19/2005


**Time:** 10:27:53 AM

**Analysis**

Low frequency transient, possibly related to utility switching or power factor capacitor switching.



## Voltage Transient and Sub-cycle Events




**Event Number:** 7

**Date:** 1/19/2005

**Time:** 3:44:00 PM

**Analysis**

Sudden change in voltage waveform / ringing - possibly related to power conditioner or resonant capacitors.




**Event Number:** 8

**Date:** 1/19/2005

**Time:** 3:44:05 PM

**Analysis**

Continued ringing waveform distortion.



**Event Number:** 11

**Date:** 1/21/2005


**Time:** 3:58:07 PM

**Analysis**


Sudden change in voltage waveform / ringing - possibly related to power conditioner or resonant capacitors.




## Voltage Transient and Sub-cycle Events



**Event Number:** 12  
**Date:** 1/21/2005  
**Time:** 3:58:07 PM  
**Analysis**  
Continued ringing waveform distortion.




**Event Number:** 13  
**Date:** 1/21/2005  
**Time:** 3:59:23 PM  
**Analysis**  
Sudden change in voltage waveform / ringing - possibly related to power conditioner or resonant capacitors.



**Event Number:** 14  
**Date:** 1/21/2005  
**Time:** 3:59:23 PM  
**Analysis**  
Continued ringing waveform distortion.




## Voltage Transient and Sub-cycle Events



**Event Number:** 15  
**Date:** 1/21/2005  
**Time:** 3:59:40 PM

### Analysis


Sudden change in voltage waveform / ringing - possibly related to power conditioner or resonant capacitors.



**Event Number:** 17  
**Date:** 1/21/2005  
**Time:** 3:59:47 PM

### Analysis

Sudden change in voltage waveform / ringing - possibly related to power conditioner or resonant capacitors.




**Event Number:** 18  
**Date:** 1/21/2005  
**Time:** 3:59:47 PM

### Analysis

Continued ringing waveform distortion.




## Voltage Transient and Sub-cycle Events



**Event Number:** 19  
**Date:** 1/21/2005  
**Time:** 3:59:57 PM

**Analysis**

Sudden change in voltage waveform / ringing - possibly related to power conditioner or resonant capacitors.



**Event Number:** 20  
**Date:** 1/21/2005  
**Time:** 3:59:57 PM

**Analysis**

Continued ringing waveform distortion.

